

CANOPY TYPE

For Use With Fire Extinguisher



1650 Series



1670 Series

Series 1650 and 1660 cabinets will accommodate a single portable Fire Extinguisher. Series 1670 will accommodate two portable Fire Extinguishers.

STANDARD EQUIPMENT

- * Heavy gauge steel construction tub, door and trim
- * White powder coat finish
- * Continuous steel piano hinge
- * Pull handle with roller catch
- * Cabinets come equipped with clear acrylic canopy

CABINET OPTIONS

- * Prefix **FR** for Fire Rated Cabinet
- * Suffix **AL** for clear anodized aluminum door and frame
- * Suffix **SS** for Stainless Steel # 4 finish door and frame
- * Door Styles See page 2-6
- * Other cabinet options See page 2-7, 2-19 and 2-20

ORDERING PROCEDURE

- * Select cabinet Figure No.
- * Select door style
- * Select Fire Extinguisher (Refer to 4000 Series)
- * Select cabinet Options

Fig. No.	Trim Style	Trim Pro. Tp	Overall Inside box dimensions			Outside dim.		Wall Opening Required			FIRE RATED CABINETS Wall Opening Required FR Option			Extinguisher Capacity
			A	B	C	D	E	Width	Height	Depth	Width	Height	Depth	
1650	Recessed	5/16"	10 1/2	24	4	13 7/8	27 3/8	11 1/2	25	4	12 1/2	26 1/8	4 7/8	2 1/2,5,10lb. ABC Dry Chem 2,2 1/2, 5 1/2,10 lb. BC 5lb. CO2 2 1/2,5lb. Halotron
1651	Semi-recessed	1 1/2"	10 1/2	24	4	13 7/8	27 3/8	11 1/2	25	2 5/8	12 1/2	26 1/8	3 1/2	
1652	recessed	3"	10 1/2	24	4	13 7/8	27 3/8	11 1/2	25	1 1/8	12 1/2	26 1/8	2	
1658	Surface		13 11/16	27 3/16	4 5/8	13 7/8	27 3/8							
1660	Recessed	5/16"	14	30	4	17 3/8	33 3/8	15	31	4	16	32 1/8	4 7/8	2 1/2,5,10,20lb.ABC Dry Chem. 2,2 1/2, 5 1/2,10,20 lb. BC 5lb.,10lb. CO2, 2 1/2 gal. W.P. 2 1/2,5lb. Halotron
1661	Semi-recessed	1 1/4"	14	30	4	17 3/8	33 3/8	15	31	2 7/8	16	32 1/8	3 3/4	
1662	recessed	2 1/2"	14	30	4	17 3/8	33 3/8	15	31	1 5/8	16	32 1/8	2 1/2	
1668	Surface		17 3/16	33 3/16	4 5/8	17 3/8	33 3/8							
1670	Recessed	5/16"	28	30	4	31 3/8	33 3/8	29	31	4	30	32 1/8	4 7/8	2 1/2,5,10,20lb.ABC Dry Chem. 2 1/2 gal. W.P.,5lb,10lb CO2
1678	Surface		31 3/16	33 3/16	4 5/8	31 3/8	33 3/8							

Note: Add 5/8" to depth of wall opening required for cabinets with aluminum frame
Fire Extinguishers must be mounted on the back of the cabinet

